

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.1105/2025

Dated: 23/06/2025

It is certified that an inspection team headed by SUNIL KUMAR (Name of Officers with designation) from... ASSISTANT ENGINEER WATER SUPPLY AND SANITATION JHUNJHANU (PHED)

Inspected the... SANJAY EDUCATION SOCIETY, TEH. MANDAWA, JHUNJHANU

(Name & Address of the school) on .....22/06/2025.....(date of inspection) and on the basis of Water Test Report (Attached) bearing no....569..... dated...23/06/2025..... Of OFFICE OF THE SENIOR CHEMIST LABORATORY (PHED Lab) certified that the SANJAY EDUCATION SOCIETY, TEH. MANDAWA, JHUNJHANU ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till...22/06/2028

अधिशायी अभियंता  
जन. स्वा. अभि. विभाग  
जिला झुझनु (राज.)

Signature with Seal: .....

Name : .....

Designation : .....

Name & Address of the Office/Department:.....

To  
SANJAY EDUCATION SOCIETY  
MANDAWA, DIST. JHUNJHANU  
(Name & Address of the Institution)

Note: The certificate is to be issued by  
authorized officer/PHED Lab/local bodies

**OFFICE OF THE SENIOR CHEMIST**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY JHUNJANU**  
**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

Not valid for legal case

No. Lab Tech(Private Chem.Rep)/2025-2026/

Date -

To,

Sanjay Education Society  
Mandawa  
Dist. Jhunjanu

District: Jhunjanu

Block : Mandawa

Reference : Your Letter No-..... Date-23.06.2025

Sample Collected By :- Manoj

Date of Receipt : 23.06.2025

Source	Permissible value as per B.I.S. 10500/2012		RO	TW
Source Location			Mandawa Dist. Jhunjanu	Mandawa Dist. Jhunjanu
Gram Panchayat			Mandawa	Mandawa
Village/Town/ City	Desirable limit	Permissible limit in absence of alternate Source	Mandawa	Mandawa
Habitation			Mandawa	Mandawa
Date of Collection			23.06.2024	23.06.2024
Date of Examination			25.06.2025	25.06.2025
Lab. Sample No.			194	195

**Note :- All results Except pH are in mg/L**

pH	6.5 to 8.5	No Relaxation	7.32	7.24
Turbidity (NTU)	1	5	Clear	Clear
Total Alkalinity (as CaCO <sub>3</sub> )	200	600	100	335
Total Hardness (as CaCO <sub>3</sub> )	200	600	50	523
Chloride (as Cl <sup>-</sup> )	250	1000	60	645
Nitrates (as NO <sub>3</sub> <sup>-</sup> )	45	45	21	37
Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	200	400	4	7
Fluoride (as F <sup>-</sup> )	1.0	1.5	0.15	1.01
Total Dissolved Solids	500	2000	235	556

**Remarks:- Sample not collected by Lab**

Senior Chemist  
PHED Lab Jhunjanu

No. Lab/Tech(Private Chem.Rep)/2025-2026/

Dated:

Copy to:

1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

Senior Chemist  
PHED Lab Jhunjanu